



June 2006

A&W Maintenance  
Attn: Mr Dan Warren; President

Re: Warren Environmental S-301 Epoxies

Warren Environmental epoxy S-301 and S-301 structural mastic applied to prepared concrete surfaces in 2000 was found to be in good condition after 66 months in service as alkalinity adjustment tank at WWTP. No delamination or separation was observed, application thickness varied from 80 to 500 mils. Tank coating included structural concrete grade beams & columns, walls and ceiling. All surfaces except floor were coated.

Thank you for an exceptional installation.

*Rick Make*

Project Engineer  
Brewing, Operations & Technology  
Utilities Group